

To: Phelps, Aaron M.[amphelps@varnumlaw.com]
Cc: Clark, Jacqueline[clark.jacqueline@epa.gov]; Williams, Thomas[williams.tom@epa.gov]; Kimble, Jeffrey[kimble.jeffrey@epa.gov]
From: Shoven, Heather
Sent: Wed 2/21/2018 11:26:17 PM
Subject: RE: Wolverine World Wide - Need for Metals Testing

Hello Mr. Phelps,

Thank you for your email below notifying EPA of this third lead test result with levels above the 15 ppb action level for drinking water systems. I wanted to follow-up on Jeff Kimble's email below and apologize for the major typo – he meant to refer **future** (not cute) communications regarding lead in drinking water to me. The auto-correct feature on the iPhone can be frustrating

I work in EPA Region 5's drinking water program and am coordinating with MDEQ on drinking water issues pertaining to the Wolverine efforts. Do you know if this third home is being provided bottled water and/or a filter at this time that is certified to remove lead? Also, do you know where the sample was collected? Did the resident collect the sample from an outdoor spigot or a tap within the home? I appreciate any additional information that you can provide.

Best wishes,

Heather

Heather A. Shoven

Compliance and Enforcement Team Leader

Ground Water and Drinking Water Branch

U.S. Environmental Protection Agency, Region 5

(312) 886-0153

From: Kimble, Jeffrey
Sent: Tuesday, February 20, 2018 12:50 PM
To: Phelps, Aaron M. <amphelps@varnumlaw.com>

Cc: Shoven, Heather <shoven.heather@epa.gov>; Clark, Jacqueline <clark.jacqueline@epa.gov>; Williams, Thomas <williams.tom@epa.gov>
Subject: Re: Wolverine World Wide - Need for Metals Testing

Thank you, please note Heather Shoven is the EPA Team Lead for the Wolverine project. Please address ~~ente~~ future communication to her as the lead. I have CC'd her on this message.

Jeff Kimble, US EPA

Cell # (734) 740-9013

On Feb 16, 2018, at 9:47 AM, Phelps, Aaron M. <amphelps@varnumlaw.com> wrote:

All,

~~We have learned of another positive lead test result (above criteria) in drinking water –~~
Ex. 6 - Personal Privacy This was another water test done by a resident at our suggestion.

We have not received any response to our January 23 letter. Is the assessment mentioned below complete? What is the government's response to this issue?

We represent over 300 area residents and they are eager for answers. Please advise.

Thank you,

Aaron Phelps
Partner
Direct: (616) 336-6257
Cell: (616) 915-2198



Varnum LLP
333 Bridge Street NW

Main: (616) 336-6000
Fax: (616) 336-7000



From: O'Donnell, David (DEQ) [<mailto:ODONNELLD@michigan.gov>]
Sent: Friday, February 02, 2018 3:26 PM
To: Phelps, Aaron M.; 'kaplan.robert@epa.gov'; 'kimble.jeffrey@epa.gov'; Grether, Heidi (DEQ)
Cc: 'chrisafendoulis@house.mi.gov'; 'robverheulen@house.mi.gov'; 'senpmacgregor@senate.michigan.gov'; Shirey, Kathleen (DEQ)
Subject: RE: Wolverine World Wide - Need for Metals Testing

Aaron:

Thank you for your note; we will assess this along with the information you provided in your letter on January 23rd. The DEQ is relieved to know via your email exchange with Mr. Kimble that the residential wells in question have been provided an alternative water supply and we will be considering these results and your other data as we consult with our colleagues in the US EPA on the response activities in Kent County.

David

David O'Donnell

Field Operations Manager - West

Remediation and Redevelopment Division

Department of Environmental Quality

525 West Allegan Street

Lansing, Michigan 48933

Phone 616-970-8561

Fax 517-241-9581

ODonnellD@michigan.gov

From: Bruins, Diane S. [<mailto:dsbruins@varnumlaw.com>] **On Behalf Of** Phelps, Aaron M.

Sent: Friday, February 02, 2018 11:38 AM

To: 'kaplan.robert@epa.gov' <kaplan.robert@epa.gov>; 'kimble.jeffrey@epa.gov' <kimble.jeffrey@epa.gov>; Grether, Heidi (DEQ) <GretherH@michigan.gov>; O'Donnell, David (DEQ) <ODONNELLD@michigan.gov>

Cc: 'chrisafendoulis@house.mi.gov' <chrisafendoulis@house.mi.gov>; 'robverheulen@house.mi.gov' <robverheulen@house.mi.gov>; 'senpmacgregor@senate.michigan.gov' <senpmacgregor@senate.michigan.gov>

Subject: Wolverine World Wide - Need for Metals Testing

Please see attached letter.

Aaron M. Phelps

Partner

Direct: (616) 336-6257

<image001.jpg>

Varnum LLP
333 Bridge Street NW
Grand Rapids, Michigan 49504

Main: (616) 336-6000
Fax: (616) 336-7000
www.varnumlaw.com